



# CHANGE REQUEST

**Request Nbr.** 000024  
**Request Date** 18-Apr-2022  
**Customer ID** 0806  
**Currency** USD  
**Project Nbr.** 21-940  
**Contract Time Change, Days**  
**Description** ASI 41 Corridor Lighting

Breiholz Construction  
1527 Maine St  
Des Moines, IA, 50314  
Phone: 515-288-6077  
Web: www.breiholz.com

## ESTIMATION

NO.	PROJECT TASK	DESCRIPTION	QTY	UOM	LINE AMT
1	Mechanical	Additional Lighting In Corridor 289	1.00	LS	3,448.71

**Approved Amount of Change (USD):** 3,448.71

## CONTRACTOR

Breiholz Construction  
1527 Maine St  
Des Moines, IA, 50314  
Phone: 515-288-6077  
Web: www.breiholz.com

18-Apr-2022

*Scott Rozenboom*

(signature)

## OWNER

Marshall County  
1 E Main St  
Marshalltown, IA, 50158

18-Apr-2022

(signature)



# ARCHITECT'S SUPPLEMENTAL INSTRUCTION

**ASI NO.: 041**

---

<b>PROJECT NAME:</b>	Marshall County Courthouse	<b>PROJECT NO:</b>	18827003
<b>CLIENT NAME:</b>	Marshall County	<b>DATE:</b>	4 February 2022
<b>PROJECT LOCATION:</b>	1 E Main St. Marshalltown, IA 50158	<b>CONTACT:</b>	Jimi Peters
<b>GENERAL CONTRACTOR:</b>	Perfection Property Restoration		

---

*The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Proceeding with the Work in accordance with these instructions indicates your acknowledgment that there will be no change in the Contract Sum or Contract Time.*

## Description:

- Revisions according to various RFIs. See associated RFIs

### *Architectural drawings*

1. **A202 – REFLECTED CEILING PLAN – LEVEL 2**
  - a. REVISE ceiling layout per existing conditions.
2. **A203 – REFLECTED CEILING PLAN – LEVEL 3**
  - a. REVISE ceiling layout per existing conditions.
3. **A621 – ENLARGED DRAWINGS – LEVEL 2 RESTROOMS**
  - a. ADD access panel location for fire smoke damper to the following drawings:
    - i. A5 & C4.
4. **A623 – ENLARGED DRAWINGS – LEVEL 3 RESTROOMS**
  - a. ADD access panel location for fire smoke damper to the following drawings:
    - i. A5 & C4.
5. **A710 – CEILING DETAILS**
  - a. REVISE ACP connection to gypsum reverse bulkhead at typical window locations.

### *Electrical drawings*

1. **EL102 – SECOND FLOOR LIGHTING PLAN**
  - a. ADD (6) F7 light fixtures to Corridor 289. Circuit and control fixtures with other corridor fixtures.
  - b. ADD (3) F8 light fixtures above desks in Corridor 289. Fixtures to be controlled via a new \$LD switch separately from the other corridor fixtures. Circuit fixtures to the corridor lighting circuit.

**Associated Submittals/RFI's:**

RFI 61, RFI 62, RFI 63, RFI 67

**Attachments:**

(6) DRAWINGS

---

Jimi Peters, AIA  
OPN Architects, Inc.