



CHANGE REQUEST

Request Nbr. 000026
Request Date 21-Apr-2022
Customer ID 0806
Currency USD
Project Nbr. 21-940
Contract Time Change, Days
Description ASI 47 Revised Duct Layout

Breiholz Construction
1527 Maine St
Des Moines, IA, 50314
Phone: 515-288-6077
Web: www.breiholz.com

ESTIMATION

NO.	PROJECT TASK	DESCRIPTION	QTY	UOM	LINE AMT
1		Revised Duct work Layout	1.00	LS	17,139.83

NOTES: Cost includes labor and materials. Insulation in attic requires foam board per spec which cost more for both labor to install and material pricing.

Approved Amount of Change (USD): 17,139.83

CONTRACTOR

Breiholz Construction
1527 Maine St
Des Moines, IA, 50314
Phone: 515-288-6077
Web: www.breiholz.com

21-Apr-2022

Scott Rozenboom

(signature)

OWNER

Marshall County
1 E Main St
Marshalltown, IA, 50158

21-Apr-2022

(signature)



ARCHITECT'S SUPPLEMENTAL INSTRUCTION

ASI NO.: 047

PROJECT NAME:	Marshall County Courthouse	PROJECT NO:	18827003
CLIENT NAME:	Marshall County	DATE:	20 March 2022
PROJECT LOCATION:	1 E Main St Marshalltown, IA 50158	CONTACT:	Jimi Peters
GENERAL CONTRACTOR:	Breiholz Construction Co.		

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Proceeding with the Work in accordance with these instructions indicates your acknowledgment that there will be no change in the Contract Sum or Contract Time.

Description:

Rerouting Return Air for on site Conditions

Architectural drawings

1. **A205 – REFLECTED CEILING PLAN LEVEL 5**
 - a. REMOVE (6x) 2x2 ceiling return grilles from ceiling cloud at “EAST LOBBY 508”
 - b. ADD (1x) 4x4 ceiling return grille to “EAST LOBBY 508”
 - c. REVISE lighting layout as illustrated.
 - d. ADD note about ceiling framing for larger return air grille.
2. **A613 – ENLARGED PLAN AND RCP – FIFTH FLOOR LOBBY**
 - a. REMOVE (6x) 2x2 ceiling return grilles from ceiling cloud at “EAST LOBBY 508”
 - b. ADD (1x) 4x4 ceiling return grille to “EAST LOBBY 508”
 - c. REVISE lighting layout as illustrated.

Mechanical drawings

1. **M105 – FIFTH FLOOR MECHANICAL PLAN**
 - a. REVISE return air routes above “EAST LOBBY 508” and North Eastern Quadrant of Building.
2. **M106 – ATTIC LEVEL FLOOR MECHANICAL PLAN**
 - a. REVISE return air routes above “EAST LOBBY 508” and North Eastern Quadrant of Building.

Associated Submittals/RFI's:

RFI 68

Attachments:

(4) DRAWINGS